



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/31/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/31/2013  
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:11 TIME OFF: 15:29  
 TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
013114-1227	Inside Work Area Front of the Electrical Box Downwind B-1	7:11	15:12	3.016	3.016	<17.56
013114-1228	Outside Work Area Personal Decon C-3	7:13	15:14	3.016	3.016	<17.56
013114-1229	Outside Work Area Waste Decon Upwind C-3	7:14	15:15	3.016	3.016	<17.56
013114-1230	Outside Work Area 2ft from Security Box Downwind B-1	7:16	15:16	3.016	3.016	<17.56
013114-1231	Outside Work Area 4ft from Security Box Downwind B-1	7:18	15:18	3.016	3.016	<17.56
013114-1232	Outside Work Area Center of North Side of Excavation Downwind C-2	7:20	15:21	3.016	3.016	<17.56
013114-1233	Outside Work Area Center of Yard Downwind B-2	7:21	15:22	3.016	3.016	<17.56
013114-1234	Outside Work Area Left of Yard Upwind B-3	7:24	15:24	3.016	3.016	<17.56
013114-1235	Outside Work Area 20ft from the Decon Upwind C-3	7:25	15:25	3.016	3.016	<17.56
013114-1236	Outside Work Area North/West Area Upwind D-3	7:27	15:27	3.016	3.016	<17.56
013114-1237	Outside Work Area 15ft from North/West Area Upwind D-3	7:29	15:29	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
11101  
Phone (718) 937-3720 Fax (718) 937-3721  
AIRTEKENV.COM

Date: 1/30/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
ROTOMETER No 1  
CALIBRATION DATE: 12/31/2013  
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
AIRTEK PROJECT #: 13-1013  
MATERIAL: Soil Excavation  
AMOUNT: \_\_\_\_\_  
TIME ON: 07:10 TIME OFF: 15:29  
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
013014-1206	Inside Work Area Fron of the Electrical Box Downwind B-1	7:10	15:11	3.016	3.016	<17.56
013014-1207	Outside Work Area Personal Decon C-3	7:12	15:12	3.016	3.016	<17.56
013014-1208	Outside Work Area Waste Decon Upwind C-3	7:15	15:15	3.016	3.016	<17.56
013014-1209	Outside Work Area 2ft from Security Box Downwind B-1	7:17	15:18	3.016	3.016	<17.56
013014-1210	Outside Work Area 4ft from Security Box Downwind B-1	7:19	15:20	3.016	3.016	<17.56
013014-1211	Outside Work Area Center of North Side of Excavation Downwind C-2	7:22	15:22	3.016	3.016	<17.56
013014-1212	Outside Work Area Center of Yard Downwind B-2	7:23	15:23	3.016	3.016	<17.56
013014-1213	Outside Work Area Left of Yard Upwind B-3	7:26	15:26	3.016	3.016	<17.56
013014-1214	Outside Work Area 20ft from the Decon Upwind C-3	7:27	15:27	3.016	3.016	<17.56
013014-1215	Outside Work Area North/West Area Upwind D-3	7:28	15:28	3.016	3.016	<17.56
013014-1216	Outside Work Area 15ft from North/West Area Upwind D-3	7:29	15:29	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE

**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-  
 3721  
 AIRTEKENV.COM

Date: 1/29/2014**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME:	<u>500 Kent Avenue</u>	PROJECT MONITOR:	<u>Gary Credille</u>
ADDRESS:	<u>500 Kent Avenue</u>	AIRTEK PROJECT #:	<u>13-1013</u>
	<u>Brooklyn, NY</u>	MATERIAL:	<u>Soil Excavation</u>
ROTOMETER No	<u>1</u>	AMOUNT:	<u></u>
CALIBRATION DATE:	<u>12/31/2013</u>	TIME ON: <u>07:08</u>	TIME OFF: <u>15:26</u>
EXPIRATION DATE:	<u>3/31/2014</u>	TOTAL # OF SAMPLES	<u>11</u>

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
012914-1185	Inside Work Area Fron of the Electrical Box Downwind B-1	7:08	15:09	3.016	3.016	<17.56
012914-1186	Outside Work Area Personal Decon C-3	7:11	15:11	3.016	3.016	<17.56
012914-1187	Outside Work Area Waste Decon Upwind C-3	7:13	15:14	3.016	3.016	<17.56
012914-1188	Outside Work Area 2ft from Security Box Downwind B-1	7:14	15:15	3.016	3.016	<17.56
012914-1189	Outside Work Area 4ft from Security Box Downwind B-1	7:16	15:17	3.016	3.016	<17.56
012914-1190	Outside Work Area Center of North Side of Excavation Downwind C-2	7:18	15:18	3.016	3.016	<17.56
012914-1191	Outside Work Area Center of Yard Downwind B-2	7:20	15:20	3.016	3.016	<17.56
012914-1192	Outside Work Area Left of Yard Upwind B-3	7:21	15:21	3.016	3.016	<17.56
012914-1193	Outside Work Area Left of South/West Side Upwind B-4	7:23	15:23	3.016	3.016	<17.56
012914-1194	Outside Work Area 20ft from the Decon Upwind C-3	7:24	15:24	3.016	3.016	<17.56
012914-1195	Outside Work Area North/West Area Upwind D-3	7:25	15:26	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-  
 3721  
 AIRTEKENV.COM

Date: 1/28/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/31/2013  
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:12 TIME OFF: 15:31  
 TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
012814-1164	Inside Work Area Fron of the Electrical Box Downwind B-1	7:12	15:12	3.016	3.016	<17.56
012814-1165	Outside Work Area Personal Decon C-3	7:13	15:13	3.016	3.016	<17.56
012814-1166	Outside Work Area Waste Decon Upwind C-3	7:15	15:15	3.016	3.016	<17.56
012814-1167	Outside Work Area 2ft from Security Box Downwind B-1	7:17	15:17	3.016	3.016	<17.56
012814-1168	Outside Work Area 4ft from Security Box Downwind B-1	7:19	15:19	3.016	3.016	<17.56
012814-1169	Outside Work Area Center of North Side of Excavation Downwind C-2	7:22	15:23	3.016	3.016	<17.56
012814-1170	Outside Work Area Center of Yard Downwind B-2	7:23	15:24	3.016	3.016	<17.56
012814-1171	Outside Work Area Left of Yard Upwind B-3	7:26	15:27	3.016	3.016	<17.56
012814-1172	Outside Work Area Left of South/West Side Upwind B-4	7:28	15:29	3.016	3.016	<17.56
012814-1173	Outside Work Area 20ft from the Decon Upwind C-3	7:29	15:30	3.016	3.016	<17.56
012814-1174	Outside Work Area North/West Area Upwind D-3	7:30	15:31	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/27/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:10 TIME OFF: 15:27
TOTAL # OF SAMPLES 11

Table with 7 columns: SAMPLE#, WORK AREA, START TIME, END TIME, INITIAL FLOW, FINAL FLOW, STRUCTURE S/PER MM^2+. Contains 13 rows of data for samples 012714-1143 to 012714-1153.

FIELD NOTES:

\*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/24/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/31/2013  
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:09 TIME OFF: 15:26  
 TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> +
012414-1122	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	15:09	3.016	3.016	<17.56
012414-1123	Outside Work Area Personal Decon C-3	7:11	15:11	3.016	3.016	<17.56
012414-1124	Outside Work Area Waste Decon Area Upwind C-3	7:12	15:12	3.016	3.016	<17.56
012414-1125	Outside Work Area 2ft from Security Box Downwind B-1	7:13	15:13	3.016	3.016	<17.56
012414-1126	Outside Work Area 4ft from Security Box Downwind B-1	7:15	15:15	3.016	3.016	<17.56
012414-1127	Outside Work Area Right of Yard Downwind B-2	7:17	15:18	3.016	3.016	<17.56
012414-1128	Outside Work Area Center of Yard Downwind B-2	7:19	15:20	3.016	3.016	<17.56
012414-1129	Outside Work Area Left of Yard Upwind B-3	7:22	15:23	3.016	3.016	<17.56
012414-1130	Outside Work Area Left of South/West Side Upwind B-4	7:23	15:24	3.016	3.016	<17.56
012414-1131	Outside Work Area Center of South/West Side Upwind B-4	7:24	15:25	3.016	3.016	<17.56
012414-1132	Outside Work Area 20ft from center of South/West Side Upwind B-4	7:26	15:26	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
11101  
Phone (718) 937-3720 Fax (718) 937-3721  
AIRTEKENV.COM

Date: 1/23/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
ROTOMETER No 1  
CALIBRATION DATE: 12/31/2013  
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille  
AIRTEK PROJECT #: 13-1013  
MATERIAL: Soil Excavation  
AMOUNT: \_\_\_\_\_  
TIME ON: 07:08 TIME OFF: 15:30  
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
012314-1101	Inside Work Area Next to the Electrical Box Downwind B-1	7:08	15:09	3.016	3.016	<17.56
012314-1102	Outside Work Area Personal Decon C-3	7:13	15:13	3.016	3.016	<17.56
012314-1103	Outside Work Area Waste Decon Area Upwind C-3	7:16	15:16	3.016	3.016	<17.56
012314-1104	Outside Work Area 2ft from Security Box Downwind B-1	7:18	15:19	3.016	3.016	<17.56
012314-1105	Outside Work Area 4ft from Security Box Downwind B-1	7:20	15:20	3.016	3.016	<17.56
012314-1106	Outside Work Area Right of Yard Downwind B-2	7:21	15:22	3.016	3.016	<17.56
012314-1107	Outside Work Area Center of Yard Downwind B-2	7:23	15:24	3.016	3.016	<17.56
012314-1108	Outside Work Area Left of Yard Upwind B-3	7:25	15:26	3.016	3.016	<17.56
012314-1109	Outside Work Area Left of South/West Side Upwind B-4	7:27	15:27	3.016	3.016	<17.56
012314-1110	Outside Work Area Center of South/West Side Upwind B-4	7:29	15:29	3.016	3.016	<17.56
012314-1111	Outside Work Area 20ft from center of South/West Side Upwind B-4	7:30	15:30	3.016	3.016	<17.56

**FIELD NOTES:**

\*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
*CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE*



## AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-  
 3721  
 AIRTEKENV.COM

Date: 1/22/2014

### DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/31/2013  
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:09 TIME OFF: 15:26  
 TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> +
012214-1080	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	15:10	3.016	3.016	<17.56
012214-1081	Outside Work Area Personal Decon C-3	7:10	15:11	3.016	3.016	<17.56
012214-1082	Outside Work Area Waste Decon Area Upwind C-3	7:11	15:12	3.016	3.016	<17.56
012214-1083	Outside Work Area 2ft from Security Box Downwind B-1	7:12	15:13	3.016	3.016	<17.56
012214-1084	Outside Work Area 4ft from Security Box Downwind B-1	7:14	15:14	3.016	3.016	<17.56
012214-1085	Outside Work Area Right of Yard Downwind B-2	7:15	15:15	3.016	3.016	<17.56
012214-1086	Outside Work Area Center of Yard Downwind B-2	7:17	15:17	3.016	3.016	<17.56
012214-1087	Outside Work Area Left of Yard Upwind B-3	7:19	15:19	3.016	3.016	<17.56
012214-1088	Outside Work Area Left of South/West Side Upwind B-4	7:22	15:22	3.016	3.016	<17.56
012214-1089	Outside Work Area Center of South/West Side Upwind B-4	7:24	15:24	3.016	3.016	<17.56
012214-1090	Outside Work Area 20ft from center of South/West Side Upwind B-4	7:26	15:26	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE





**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/21/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/31/2013  
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:11 TIME OFF: 14:25  
 TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES /PER MM <sup>2</sup> *
012114-1059	Inside Work Area Next to the Electrical Box Upwind B-1	7:11	14:11	3.016	3.016	<14.63
012114-1060	Outside Work Area Personal Decon C-3	7:13	14:13	3.016	3.016	<14.63
012114-1061	Outside Work Area Waste Decon Area Downwind C-3	7:15	14:15	3.016	3.016	<14.63
012114-1062	Outside Work Area 2ft from Security Box Upwind B-1	7:16	14:17	3.016	3.016	<14.63
012114-1063	Outside Work Area 4ft from Security Box Upwind B-1	7:17	14:18	3.016	3.016	<14.63
012114-1064	Outside Work Area Right of Yard Upwind B-2	7:18	14:19	3.016	3.016	<14.63
012114-1065	Outside Work Area Center of Yard Upwind B-2	7:19	14:20	3.016	3.016	<14.63
012114-1066	Outside Work Area Left of Yard Downwind B-3	7:20	14:21	3.016	3.016	<14.63
012114-1067	Outside Work Area Left of South/West Side Downwind B-4	7:21	14:22	3.016	3.016	<14.63
012114-1068	Outside Work Area Center of South/West Side Downwind B-4	7:23	14:23	3.016	3.016	<14.63
012114-1069	Outside Work Area 20ft Center of South/West Side Downwind B-	7:25	14:25	3.016	3.016	<14.63

**FIELD NOTES:**

\*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
11101  
Phone (718) 937-3720 Fax (718) 937-  
3721  
AIRTEKENV.COM

Date: 1/20/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
ROTOMETER No 1  
CALIBRATION DATE: 12/31/2013  
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
AIRTEK PROJECT #: 13-1013  
MATERIAL: Soil Excavation  
AMOUNT: \_\_\_\_\_  
TIME ON: 07:11 TIME OFF: 15:27  
TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES /PER MM <sup>2</sup> *
012014-1038	Inside Work Area Next to the Electrical Box Downwind B-1	7:11	15:12	3.016	3.016	<17.56
012014-1039	Outside Work Area Personal Decon C-3	7:13	15:14	3.016	3.016	<17.56
012014-1040	Outside Work Area Waste Decon Area Upwind C-3	7:15	15:16	3.016	3.016	<17.56
012014-1041	Outside Work Area 2ft from Security Box Downwind B-1	7:16	15:17	3.016	3.016	<17.56
012014-1042	Outside Work Area 4ft from Security Box Downwind B-1	7:17	15:18	3.016	3.016	<17.56
012014-1043	Outside Work Area Right of Yard Downwind B-2	7:18	15:19	3.016	3.016	<17.56
012014-1044	Outside Work Area Center of Yard Downwind B-2	7:20	15:20	3.016	3.016	<17.56
012014-1045	Outside Work Area Left of Yard Upwind B-3	7:21	15:21	3.016	3.016	<17.56
012014-1046	Outside Work Area Left of South/West Side Upwind B-4	7:23	15:23	3.016	3.016	<17.56
012014-1047	Outside Work Area Center of South/West Side Upwind B-4	7:25	15:25	3.016	3.016	<17.56
012014-1048	Outside Work Area 20ft Center of South/West Side Upwind B-4	7:27	15:27	3.016	3.016	<17.56

**FIELD NOTES:**

\*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-  
 3721  
 AIRTEKENV.COM

Date: 1/17/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/31/2013  
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:10 TIME OFF: 15:32  
 TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2*</sup>
011714-1017	Inside Work Area Next to the Electrical Box Upwind B-1	7:10	15:11	3.016	3.016	<17.56
011714-1018	Outside Work Area Personal Decon C-3	7:12	15:12	3.016	3.016	<17.56
011714-1019	Outside Work Area Waste Decon Area Downwind C-3	7:14	15:15	3.016	3.016	<17.56
011714-1020	Outside Work Area 2ft from Security Box Upwind B-1	7:17	15:17	3.016	3.016	<17.56
011714-1021	Outside Work Area 4ft from Security Box Upwind B-1	7:19	15:19	3.016	3.016	<17.56
011714-1022	Outside Work Area Right of Yard Upwind B-2	7:22	15:23	3.016	3.016	<17.56
011714-1023	Outside Work Area Center of Yard Upwind B-2	7:24	15:24	3.016	3.016	<17.56
011714-1024	Outside Work Area Left of Yard Downwind B-3	7:26	15:26	3.016	3.016	<17.56
011714-1025	Outside Work Area Left of South/West Side Downwind B-4	7:28	15:28	3.016	3.016	<17.56
011714-1026	Outside Work Area Center of South/West Side Downwind B-4	7:30	15:30	3.016	3.016	<17.56
011714-1027	Outside Work Area Right of South/West Side Downwind B-4	7:32	15:32	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/16/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/31/2013  
 EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Creddille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:11 TIME OFF: 15:29  
 TOTAL # OF SAMPLES 11

SAMPLE#	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
011614-996	Inside Work Area Next to the Electrical Box Upwind B-1	7:11	15:11	3.016	3.016	<17.56
011614-997	Outside Work Area Personal Decon C-3	7:13	15:14	3.016	3.016	<17.56
011614-998	Outside Work Area Waste Decon Area Downwind C-3	7:15	15:16	3.016	3.016	<17.56
011614-999	Outside Work Area 2ft from Security Box Upwind B-1	7:16	15:17	3.016	3.016	<17.56
011614-1000	Outside Work Area 4ft from Security Box Upwind B-1	7:18	15:18	3.016	3.016	<17.56
011614-1001	Outside Work Area Right of Yard Upwind B-2	7:20	15:20	3.016	3.016	<17.56
011614-1002	Outside Work Area Center of Yard Upwind B-2	7:21	15:21	3.016	3.016	<17.56
011614-1003	Outside Work Area Left of Yard Downwind B-3	7:23	15:23	3.016	3.016	<17.56
011614-1004	Outside Work Area Left of South/West Side Downwind B-4	7:25	15:25	3.016	3.016	<17.56
011614-1005	Outside Work Area Center of South/West Side Downwind B-4	7:27	15:27	3.016	3.016	<17.56
011614-1006	Outside Work Area Right of South/West Side Downwind A-4	7:29	15:29	3.016	3.016	<17.56

**FIELD NOTES:**

\*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
11101  
Phone (718) 937-3720 Fax (718) 937-3721  
AIRTEKENV.COM

Date: 1/15/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
ROTOMETER No 1  
CALIBRATION DATE: 12/31/2013  
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille  
AIRTEK PROJECT #: 13-1013  
MATERIAL: Soil Excavation  
AMOUNT: \_\_\_\_\_  
TIME ON: 07:12 TIME OFF: 15:32  
TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
011514-975	Inside Work Area Next to the Electrical Box Upwind B-1	7:09	15:09	3.016	3.016	<17.56
011514-976	Outside Work Area Personal Decon C-3	7:10	15:10	3.016	3.016	<17.56
011514-977	Outside Work Area Waste Decon Area Downwind C-3	7:12	15:12	3.016	3.016	<17.56
011514-978	Outside Work Area 2ft from Security Box Upwind B-1	7:14	15:15	3.016	3.016	<17.56
011514-979	Outside Work Area 4ft from Security Box Upwind B-1	7:17	15:17	3.016	3.016	<17.56
011514-980	Outside Work Area Right of Yard Upwind B-2	7:19	15:19	3.016	3.016	<17.56
011514-981	Outside Work Area Center of Yard Upwind B-2	7:22	15:23	3.016	3.016	<17.56
011514-982	Outside Work Area Left of Yard Downwind B-3	7:24	15:25	3.016	3.016	<17.56
011514-983	Outside Work Area Left of South/West Side Downwind B-4	7:26	15:26	3.016	3.016	<17.56
011514-984	Outside Work Area Center of South/West Side Downwind B-4	7:28	15:28	3.016	3.016	<17.56
011514-985	Outside Work Area Right of South/West Side Downwind A-4	7:30	15:30	3.016	3.016	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City 11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/14/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:12 TIME OFF: 15:32
TOTAL # OF SAMPLES 11

Table with 7 columns: SAMPLE #, WORK AREA, START TIME, END TIME, INITIAL FLOW, FINAL FLOW, STRUCTURE S/PER MM²\*. Contains 11 rows of sampling data.

FIELD NOTES:

\*STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/13/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No 1
CALIBRATION DATE: 12/31/2013
EXPIRATION DATE: 3/31/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:10 TIME OFF: 15:31
TOTAL # OF SAMPLES 11

Table with 7 columns: SAMPLE #, WORK AREA, START TIME, END TIME, INITIAL FLOW, FINAL FLOW, STRUCTURES/PER MM^2. Contains 11 rows of sampling data.

FIELD NOTES:
\*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/10/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No omega HF-10  
 CALIBRATION DATE: 12/17/2013  
 EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:00 TIME OFF: 15:30  
 TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
011014-912	Inside Work Area Next to the Electrical Box Downwind B-1	7:08	15:09	3.46	3.46	<17.56
011014-913	Outside Work Area Personal Decon C-3	7:11	15:11	3.46	3.46	<17.56
011014-914	Outside Work Area Waste Decon Area Upwind C-3	7:13	15:14	3.46	3.46	<17.56
011014-915	Outside Work Area 2ft from Security Box Downwind B-1	7:15	15:16	3.46	3.46	<17.56
011014-916	Outside Work Area 4ft from Security Box Downwind B-1	7:16	15:17	3.46	3.46	<17.56
011014-917	Outside Work Area Right of Yard Downwind B-2	7:20	15:20	3.46	3.46	<17.56
011014-918	Outside Work Area Center of Yard Downwind B-2	7:21	15:21	3.46	3.46	<17.56
011014-919	Outside Work Area Left of Yard Upwind B-3	7:23	15:23	3.46	3.46	<17.56
011014-920	Outside Work Area Left of South/West Side Upwind B-4	7:25	15:26	3.46	3.46	<17.56
011014-921	Outside Work Area Center of South/West Side Upwind B-4	7:27	15:28	3.46	3.46	<17.56
011014-922	Outside Work Area Right of South/West Side Upwind A-4	7:29	15:29	3.46	3.46	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE





**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
11101  
Phone (718) 937-3720 Fax (718) 937-3721  
AIRTEKENV.COM

Date: 1/9/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
ROTOMETER No: omega HF-10  
CALIBRATION DATE: 12/17/2013  
EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille  
AIRTEK PROJECT #: 13-1013  
MATERIAL: Soil Excavation  
AMOUNT: \_\_\_\_\_  
TIME ON: 07:00 TIME OFF: 15:30  
TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
010914-891	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	15:09	3.46	3.46	<17.56
010914-892	Outside Work Area Personal Decon C-3	7:10	15:10	3.46	3.46	<17.56
010914-893	Outside Work Area Waste Decon Area Upwind C-3	7:12	15:12	3.46	3.46	<17.56
010914-894	Outside Work Area 2ft from Security Box Downwind B-1	7:14	15:15	3.46	3.46	<17.56
010914-895	Outside Work Area 4ft from Security Box Downwind B-1	7:17	15:18	3.46	3.46	<17.56
010914-896	Outside Work Area Right of Yard Downwind B-2	7:19	15:20	3.46	3.46	<17.56
010914-897	Outside Work Area Center of Yard Downwind B-2	7:22	15:23	3.46	3.46	<17.56
010914-898	Outside Work Area Left of Yard Upwind B-3	7:24	15:24	3.46	3.46	<17.56
010914-899	Outside Work Area Left of South/West Side Upwind B-4	7:26	15:26	3.46	3.46	<17.56
010914-900	Outside Work Area Center of South/West Side Upwind B-4	7:28	15:28	3.46	3.46	<17.56
010914-901	Outside Work Area Right of South/West Side Upwind A-4	7:30	15:30	3.46	3.46	<17.56

**FIELD NOTES:**

\*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE

\_\_\_\_\_  
\_\_\_\_\_



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City
11101
Phone (718) 937-3720 Fax (718) 937-3721
AIRTEKENV.COM

Date: 1/8/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue
ADDRESS: 500 Kent Avenue
Brooklyn, NY
ROTOMETER No: omega HF-10
CALIBRATION DATE: 12/17/2013
EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille
AIRTEK PROJECT #: 13-1013
MATERIAL: Soil Excavation
AMOUNT:
TIME ON: 07:00 TIME OFF: 15:30
TOTAL # OF SAMPLES 11

Table with 7 columns: SAMPLE #, WORK AREA, START TIME, END TIME, INITIAL FLOW, FINAL FLOW, STRUCTURE S/PER MM^2. Contains 11 data rows and 18 empty rows.

FIELD NOTES:

\*STRUCTURES /PER MM^2 - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE
CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



AIRTEK ENVIRONMENTAL CORP.

39-37 29th Street, Long Island City 11101 Phone (718) 937-3720 Fax (718) 937-3721 AIRTEKENV.COM

Date: 1/7/2014

DAILY ASBESTOS AIR SAMPLING LOG

PROJECT NAME: 500 Kent Avenue ADDRESS: 500 Kent Avenue Brooklyn, NY ROTOMETER No: omega HF-10 CALIBRATION DATE: 12/17/2013 EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille AIRTEK PROJECT #: 13-1013 MATERIAL: Soil Excavation AMOUNT: TIME ON: 07:00 TIME OFF: 13:50 TOTAL # OF SAMPLES 11

Table with 7 columns: SAMPLE #, WORK AREA, START TIME, END TIME, INITIAL FLOW, FINAL FLOW, STRUCTURE S/PER MM²\*. Contains 11 rows of sampling data.

FIELD NOTES:

\*STRUCTURES /PER MM² - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/6/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME:	<u>500 Kent Avenue</u>	PROJECT MONITOR:	<u>Gary Credille</u>
ADDRESS:	<u>500 Kent Avenue</u>	AIRTEK PROJECT #:	<u>13-1013</u>
	<u>Brooklyn, NY</u>	MATERIAL:	<u>Soil Excavation</u>
ROTOMETER No	<u>omega HF-10</u>	AMOUNT:	<u></u>
CALIBRATION DATE:	<u>12/17/2013</u>	TIME ON: <u>07:00</u> TIME OFF: <u>15:30</u>	
EXPIRATION DATE:	<u>3/17/2014</u>	TOTAL # OF SAMPLES	<u>11</u>

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
010614-828	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	15:09	3.46	3.46	<17.56
010614-829	Outside Work Area Personal Decon C-3	7:11	15:11	3.46	3.46	<17.56
010614-830	Outside Work Area Waste Decon Area Upwind C-3	7:13	15:13	3.46	3.46	<17.56
010614-831	Outside Work Area 2ft from Security Box Downwind B-1	7:15	15:16	3.46	3.46	<17.56
010614-832	Outside Work Area 4ft from Security Box Downwind B-1	7:16	15:17	3.46	3.46	<17.56
010614-833	Outside Work Area Right of Yard Downwind B-2	7:18	15:18	3.46	3.46	<17.56
010614-834	Outside Work Area Center of Yard Downwind B-2	7:20	15:20	3.46	3.46	<17.56
010614-835	Outside Work Area Left of Yard Upwind B-3	7:21	15:21	3.46	3.46	<17.56
010614-836	Outside Work Area Left of South/West Side Upwind B-4	7:23	15:23	3.46	3.46	<17.56
010614-837	Outside Work Area Center of South/West Side Upwind B-4	7:25	15:25	3.46	3.46	<17.56
010614-838	Outside Work Area Right of South/West Side Upwind A-4	7:26	15:26	3.46	3.46	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/3/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No omega HF-10  
 CALIBRATION DATE: 12/17/2013  
 EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:00 TIME OFF: 14:30  
 TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURES /PER MM <sup>2</sup> +
010314-807	Inside Work Area Next to the Electrical Box Downwind B-1	7:09	14:10	3.46	3.46	<17.56
010314-808	Outside Work Area Personal Decon C-3	7:10	14:11	3.46	3.46	<17.56
010314-809	Outside Work Area Waste Decon Area Upwind C-3	7:12	14:12	3.46	3.46	<17.56
010314-810	Outside Work Area 2ft from Security Box Downwind B-1	7:14	14:15	3.46	3.46	<17.56
010314-811	Outside Work Area 4ft from Security Box Downwind B-1	7:17	14:17	3.46	3.46	<17.56
010314-812	Outside Work Area Right of Yard Downwind B-2	7:19	14:19	3.46	3.46	<17.56
010314-813	Outside Work Area Center of Yard Downwind B-2	7:22	14:22	3.46	3.46	<17.56
010314-814	Outside Work Area Left of Yard Upwind B-3	7:24	14:24	3.46	3.46	<17.56
010314-815	Outside Work Area Left of South/West Side Upwind B-4	7:25	14:26	3.46	3.46	<17.56
010314-816	Outside Work Area Center of South/West Side Upwind B-4	7:27	14:28	3.46	3.46	<17.56
010314-817	Outside Work Area Right of South/West Side Upwind A-4	7:29	14:30	3.46	3.46	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE



**AIRTEK ENVIRONMENTAL CORP.**

39-37 29th Street, Long Island City  
 11101  
 Phone (718) 937-3720 Fax (718) 937-3721  
 AIRTEKENV.COM

Date: 1/2/2014

**DAILY ASBESTOS AIR SAMPLING LOG**

PROJECT NAME: 500 Kent Avenue  
 ADDRESS: 500 Kent Avenue  
Brooklyn, NY  
 ROTOMETER No 1  
 CALIBRATION DATE: 12/17/2013  
 EXPIRATION DATE: 3/17/2014

PROJECT MONITOR: Gary Credille  
 AIRTEK PROJECT #: 13-1013  
 MATERIAL: Soil Excavation  
 AMOUNT: \_\_\_\_\_  
 TIME ON: 07:10 TIME OFF: 15:30  
 TOTAL # OF SAMPLES 11

SAMPLE #	WORK AREA	START TIME	END TIME	INITIAL FLOW	FINAL FLOW	STRUCTURE S/PER MM <sup>2</sup> *
010214-786	Inside Work Area Next to the Electrical Box Upwind B-1	7:10	15:10	3.46	3.46	<17.56
010214-787	Outside Work Area Personal Decon C-3	7:11	15:12	3.46	3.46	<17.56
010214-788	Outside Work Area Waste Decon Area Downwind C-3	7:13	15:13	3.46	3.46	<17.56
010214-789	Outside Work Area 2ft from Security Box Upwind B-1	7:15	15:15	3.46	3.46	<17.56
010214-790	Outside Work Area 4ft from Security Box Upwind B-1	7:16	15:17	3.46	3.46	<17.56
010214-791	Outside Work Area Right of Yard Upwind B-2	7:18	15:19	3.46	3.46	<17.56
010214-792	Outside Work Area Center of Yard Upwind B-2	7:20	15:20	3.46	3.46	<17.56
010214-793	Outside Work Area Left of Yard Downwind B-3	7:21	15:21	3.46	3.46	<17.56
010214-794	Outside Work Area Left of South/West Side Downwind B-4	7:23	15:23	3.46	3.46	<17.56
010214-795	Outside Work Area Center of South/West Side Downwind B-4	7:24	15:24	3.46	3.46	<17.56
010214-796	Outside Work Area Right of South/West Side Downwind A-4	7:26	15:26	3.46	3.46	<17.56

**FIELD NOTES:**  
 \*STRUCTURES /PER MM<sup>2</sup> - INDICATES NUMBER OF STRUCTURES IDENTIFIED PER MILLIMETER SQUARE  
 CLEAN AIR LIMIT IS LESS THAN OR EQUAL TO 70 ASBESTOS STRUCTURES PER MILLIMETER SQUARE